

DEPARTMENT OF MICROBIOLOGY
AGMC & GBP HOSPITAL

Ref no: 18/Micro/AGMC/Water Sterility/7.10.2019

To

✓ Neha Gupta, Capt

O/C Health Sec

182 Military Hospital

Agartala, Tripura.

Date- 09/10/2019


Sub- Report of microbiological sterility testing of 1 no. water sample

Sir,

I am herewith submitting the sterility report of 1 no. water sample received on 3/10/2019 at 10:35 am. Details of the investigation are as follows:

Sl. no	Place of collection	Source	Date and Time	Coliform detected or not	MPN/100ml	Remarks
1	Pump House No 2	Bore well	3/10/19 10:35am	Detected	9	Acceptable but make regular sanitary checks

Yours sincerely


I/C Head of Department, Microbiology
Agartala Government Medical College
Agartala, Tripura (W)

1. Office copy, Microbiology

2. IDSP Office


Riaz Hossain
Maj
Army Medical Corps

WATER SAFETY CERTIFICATE

Certified that water supplied to Army Public School Agartala is safe , potable, piped and chlorinated. It is fit for human consumption, storage facility is safe & adequate.

Case No : 330204/APSA/2019/784

Unit : Agartala Army Cantt

Date : 10 Jan 2020



Riaz
JEEIM

Riaz Hossain

Maj


COUNTERSIGNED BY

The water supplied to APS is fit for consumption. Report of Microbiological testing by Agartala Medical College is attached along with this certificate

Case No : 330204/APSA/2019/784

Unit : Agartala Army Cantt

Date : 10 Jan 2020



Rajesh
Rajesh Nair
Lt Col
SEMO